

# TLN WRO Technical Processes type Document

< Co-location and physical interconnect >



# telenet

## Document Housekeeping

### Document Category and type

CAT	TYPE	DOC ID	Comment
Technical Processes	TPRC	TLN_WRO_TA_T_T_PAAA	Technical Process type documents (TPRC) describes technical procedures for exchanging information and interacting between Telenet and the AO.

### Document Status

EDITION	DATE	STATUS
1.0	09.10.2013	Final
2.0	29.12.2018	Final

### Legal Disclaimer

“This document constitutes an integral part of the Telenet Reference Offer for Basic TV / IDTV / BB and should be fully complied with by the Beneficiary at all times. Non compliance, incomplete or deviating application of this document by the Beneficiary, or his authorized agent, results in the suspension and ultimately termination of the Contract between Telenet and the Beneficiary.

At any time this document is susceptible to change by Telenet, Regulator’s decision or by decision of a relevant judicial authority. Changes to this document will, depending on the circumstances for change, be appropriately notified to the Beneficiary and published on the Telenet website.

Telenet has appealed the CRC decisions of the VRM, BIPT and CSA of 29 June 2018 concerning the market analysis of the broadband and broadcasting market in Belgium and it consequently reserves all its rights in relation to this document.”

## Table of Contents

1	Abstract .....	5
2	Technical process: < Co-location procedures> .....	6
2.1	DETAILED SCOPE AND PURPOSE.....	6
2.2	APPLICATION DOMAIN.....	6
2.3	SHORT DESCRIPTION OF PROCEDURE.....	6
2.4	PROCEDURE SPECIFIC TIME TABLES .....	6
3	Technical process: < Telenet Co-location procedures> .....	7
3.1	INTRODUCTION .....	7
3.2	GENERAL ARCHITECTURE PHYSICAL INTERCONNECTS .....	7
3.3	PHYSICAL INTERCONNECT TYPES .....	7
3.4	PHYSICAL INTERCONNECT MECHANICS .....	8
3.5	PHYSICAL INTERCONNECT TRANSPORT LINKS .....	8

3.6	PHYSICAL INTERCONNECT POWER AND HVAC SUPPLY .....	8
3.7	PHYSICAL INTERCONNECT ENVIRONMENTAL REQUIREMENTS .....	9
3.8	PHYSICAL INTERCONNECT SAFETY REQUIREMENTS .....	9

[No table of figures entries found.](#)

## List of Appendixes

This document may refer to further detailed documents that are added in Appendixes to this document.

A reference to an appendix is in this document highlighted with grey background.

The list with appendixes of this document:

None.

## List of References

This document may refer to external documents or information sources.

A reference to an external document or information source is in this document highlighted with grey background.

The list of referred external documents or information sources in this document:

None.

## Restricted information

This document may contain sections that are not public information and that can be made available only to Parties that have executed specific NDA`s.

Information that is subject to NDA is marked in this document as follows:

NDA  
NDA

The information in this text box is available only under NDA

Before conversion to PDF format for publication of the document, the information will be made unreadable by converting the background of the text box to black.

## 1 Abstract

This document describes the co-location procedures that will be in effect to allow the AO to connect its infrastructure to the TLN network interfaces.

## **2 Technical process: < Co-location procedures >**

### **2.1 Detailed scope and purpose**

- (1) This procedure governs the procedures that will be in place in order to realize the necessary Ethernet interconnections between the Telenet Network and the AO network in the locations as required by the TLN WRO.
- (2) The physical interconnections between Telenet and the AO will be located in one or multiple Telenet Switching Offices (SO). Traffic is routed over these interconnect links between Telenet and the AO. If need be, traffic can be logically separated by means of VLANs (802.1q) over the interconnect links.
- (3) In case the AO wishes to do so Telenet offers the possibility for physical co-location at the Telenet RPOI's.

### **2.2 Application domain**

- (4) This technical process is applicable in all cases where an AO wants to become a Beneficiary for any of the Telenet Reference Offers:
  - Telenet Reference Offer Basic TV (ROTV)
  - Annex Interactive Services (AIDTV) (option on ROTV)
  - Telenet Reference Offer Broadband Services (ROBB)
- (5) The precise interconnection requirements are described further in section 5 of this document.

### **2.3 Short description of procedure**

- (6) During the initial implementation and test technical project, the interconnection requirements will be reviewed to the various available options as described in section 3 of this document.
- (7) After agreement, the realization of the interconnection(s) will then become part of the overall initial implementation plan and will be governed by the same SOW.

### **2.4 Procedure specific time tables**

- (8) The implementation of interconnect links will be realized in a “project” mode as part of the initial implementation project. The realization time for the links will typically be dependent mostly on the time required to implement the physical fiber links. Even in the case where the AO decides to order commercial products from the TLN carrier division, implementation lead time can only be given once concrete AO location(s) are known and TLN has had the opportunity to verify the connectivity options for its fiber network in this location(s) and can assess eventual required “fiber lay” works.
- (9) Once the fiber cable is in place and the AO has installed and activated the required optical xWDM equipment, typically a “commissioning” period of 4 calendar weeks will apply, during which TLN will activate and test the connection in an end to end way and enables it for data transport.

### **3 Technical process: < Telenet Co-location procedures>**

#### **3.1 Introduction**

- (10) In order to allow an AO to make use of the TLN WRO, technical Ethernet interconnection(s) will need to be realized between the Telenet Network and the AO network in various locations. Physical interconnect(s) between Telenet and the AO can carry the IP traffic from multiple Telenet sites, the Switching Office (SO) locations, for a given TLN Reference Offer. If required, this traffic could be logically separated on the same physical link by means of VLANs.

#### **3.2 General architecture physical interconnects**

- (11) There will be minimum one redundant physical interconnection in one of the RPOI's. This physical connection will be used for BB traffic which is aggregated for all RPOI traffics carried by VLANs.
- (12) In case the AO wants to start with only one interconnection, the RPOI will be in one of the regions to be selected by Telenet.  
The Telenet RPOI's are located in the following regions Asse, Hoboken, Mechelen, Gent and Hasselt.  
The addresses of the RPOI's are respectively:

Hoboken: Boombekelaan 14, 2660 Hoboken  
Asse: Brusselsesteenweg 464, 1730 Asse  
Gent: Bomastraat 11, 9000 Gent  
Hasselt: Gouverneur Verwilghensingel 32, 3500 Hasselt  
Roeselare: Hof ter Weze 10, 8800 Roeselare

Geo Back-up site: Mechelen: Liersesteenweg 4, 2800 Mechelen

- (13) There will be a restriction for the aggregated bandwidth of logical RPOI links. If these links exceed a certain bandwidth, more physical RPOI connections need to be added.  
The order in which the RPOI's need to be added will be defined by Telenet taking into account the characteristics of the AO traffic resulting from the AO end-users. The purpose of adding RPOI's should be to have the traffic spread out evenly throughout the Telenet network bearing in mind that offload of the AO traffic should be done as close to the source as possible.
- (14) For VOD, there will be a second redundant physical interconnection in one of the RPOI's.  
This physical connection will be used for VoD traffic which is aggregated for all RVSA traffics carried by VLANs.
- (15) There will be a restriction for the aggregated bandwidth of logical RVSA links. If these links exceed a certain bandwidth, more physical RVSA connections need to be added.

In principle no AO networking equipment is required in the Telenet facilities. The AO installs his equipment in its premises and brings an optical connection from its network equipment towards the relevant Telenet buildings. However, if the the AO wishes to do so Telenet offers the possibility for physical co-location at the Telenet RPOI's.

#### **3.3 Physical interconnect types**

- (16) There are 2 types of physical interconnect types that may need to be realized, depending on the type of RO's the AO subscribes to:
- o Interconnect at one of the RPOI's (for data traffic)
  - o Interconnect at one of the RPOI's (for VOD & Management traffic)
- (17) Each of the 2 physical interconnect types are realized in the same way:

- Optical interconnect on a fiber, using xWDM as physical transport and multiplexing layer
- (18) Becoming Beneficiary of the ROTV implies following physical interconnects to be realized:
- Interconnect at one of the RPOI's for Management Link
- (19) Becoming Beneficiary of the ROTV with option AIDTV implies following physical interconnects to be realized:
- In the case the AO makes use of the Telenet Network for the STB return path:
- Interconnect at one of the RPOI's (for data traffic)
  - Interconnect at one of the RPOI's (for VOD and Management traffic)
- In the case the AO does not use the Telenet Network for the STB return path:
- Interconnect at one of the RPOI's (for VOD and Management traffic)
- (20) Becoming Beneficiary of the ROBB implies following physical interconnects to be realized:
- Interconnect at one of the RPOI's (for data traffic)
- (21) Besides physical Interconnect it can be required to establish virtual (VPN) connectivity over the public Internet for specific management traffic ( such as provisioning, access to test environments, accounting etc )

### 3.4 Physical interconnect mechanics

- (22) The AO incoming fiber cable(s) are mechanically fixed and terminated in the fiber shelves located on top of the AO intake rack.
- (23) From the AO intake rack, TLN will make the necessary connections to the Telenet interconnect router handling the AO traffic.

### 3.5 Physical interconnect transport links

- (24) The AO has several options for implementing the physical transport links, as described above, between its premises and the TLN location(s):
- Making use of the commercial leased line service offering of the Telenet carrier business division that offers various solutions for implementing xWDM over optical fiber link connections as described above, between the AO premises and the TLN location(s)
  - The AO can also make use of its own fiber infrastructure and bring its fiber to the TLN location(s).
  - The AO can make use of third party fiber / leased line infrastructure providers that are capable of realizing the required connections

In addition to these cases the AO has the possibility to request co-location services at Telenet as described below.

### 3.6 Physical interconnect Power and HVAC supply

- (25) As the TLN solution for interconnect does not require AO equipment to be located inside TLN premises there are also no requirements for power and HVAC supply applicable to AO. But when the AO rents rackspace then Telenet will provide power and HVAC. In that case requirements will be provided during initial project.
- (26) The intake rack and equipment used for termination of the fiber of the AO will be powered and cooled by TLN in accordance with its own practices for such type of equipment.



### 3.7 Physical interconnect environmental requirements

- (26)As the TLN solution for interconnect does not require AO equipment to be located inside TLN premises there are also no environmental requirements applicable to AO. But when the AO rents rackspace then Telenet will provide environmental requirements during initial project.

### 3.8 Physical interconnect safety requirements

- (27)As the TLN solution for interconnect does not require AO equipment to be located inside TLN premises and hence there is no need for AO technical personnel to enter into TLN technical buildings there are also no safety requirements applicable to AO personnel. But when the AO rents rackspace then Telenet will provide safety requirements during initial project.

### 3.9 Co-location at Telenet RPOI

- (28)In case the AO wishes to do so Telenet offers physical co-location at the RPOI's. Physical co-location can consist in a separate room inside the Telenet building or co-mingling. If no sufficient space is available inside the Telenet building, Telenet will analyse the possibility of outdoor location.
- (29)The preferred solution for co-location that will be offered to an AO will be determined taking into account the solution provided to other AO's at the same location. Meaning that in case Telenet already built a co-location room inside the Telenet building/RPOI that provided for sufficient space for different AO's, priority should be given to this solution also for other AO's.
- (30)All AO's that have subscribed to the co-location offer should exercise their rights with respect and without causing any discomfort for Telenet or other Beneficiaries using the co-location area. In any event, all technicians entering the co-location area on behalf of the Beneficiary should be reported to Telenet and need to sign the Co-location Code of Conduct included in enclosures "TLN\_WRO\_TA\_T\_T\_PAAB - Co-location Code of Conduct".
- (31)In order to set-up a co-location the Beneficiary should send a request to Telenet including the following relevant details: (i) define location of the requested co-location (which RPOI) and (ii) define timing for enabling the co-location bearing in mind the minimum time to set-up a co-location by Telenet of minimum 6 months (excluding possible fibre works).
- (32)Telenet will be responsible for the technical set-up of the co-location (set-up of the rack, providing of A&B power feed, connection with the BNG's through the SR patch panel). The Beneficiary will be responsible for setting up the fibre connection with the co-location rack.
- (33)Recurring costs linked to the use of the co-location are defined in the relevant enclosures "TLN\_WRO\_GA\_G\_P\_PAAA \_ Tarification Basic TV" and "TLN\_WRO\_GA\_G\_P\_PAAB \_ Tarification Bundle TV\_BB".